

DEPARTMENT OF THE ARMY
Omaha District, Corps of Engineers
106 South 15th Street
Omaha, Nebraska 68102-1618

:NOTICE: Failure to acknowledge : Solicitation No. DACA45 02 R 0007
:all amendments may cause rejec- :
:tion of the offer. See FAR : Date of Issue: 18 JAN 2002
:52.215-1 of Section 00100 : Date of Receiving Proposals:
7 MAR 2002

Amendment No. 0001
22 February 2002

SUBJECT: Amendment No. 0001 to Request for Proposal Solicitation Package
for Design and Construction of BULK FUEL STORAGE TANK, POPE AFB,
NORTH CAROLINA.
Solicitation No. DACA45 02 R 0007.

TO: Prospective Offerors and Others Concerned

1. The specifications and drawings for subject project are hereby modified
as follows (revise all specification indices, attachment lists, and drawing
indices accordingly).

a. Specifications. (Descriptive Changes.)

(1) Section 13110A, Page 7, paragraph 1.3, lines 3 through 10
from top of page, delete the second and third sentence of
paragraph "In addition to the minimum requirements of these
specifications ... under the slab or floor foundation.", and
substitute the following sentence:

"The services required include planning, installation, adjusting and
testing of a cathodic protection system, using sacrificial anodes for
cathodic protection of post indicator valves on the storm drain lines."

(2) Section 13110A, Page 9, delete paragraphs 1.3.6, 1.3.6.1,
and 1.3.6.2 in their entirety and substitute "1.3.6 Not Used".

(3) Section 13110A, Page 10, paragraph 1.3.11, delete
subparagraphs 1.3.11 b., 1.3.11 c., 1.3.11 e., and 1.3.11 f. in
their entirety and renumber subparagraph 1.3.11 "d. Valves" as
"b. Valves".

(4) Section 13110A, Page 16, delete paragraph 2.2.16 in its
entirety and substitute "2.2.16 Not Used".

(5) Section 13110A, Page 17, delete paragraph 3.1.2 in its
entirety.

(6) Section 13110A, Page 20, delete paragraph 3.3.2 in its
entirety.

(7) Section 13110A, Page 21, delete paragraph 3.5.4.2 in its
entirety and substitute "3.5.4.2 Not Used".

2. This amendment is a part of the proposing papers and its receipt shall be acknowledged on the Standard Form 1442. All other conditions and requirements of the request for proposal remain unchanged. If the proposals have been mailed prior to receiving this amendment, you will notify the office where proposals are received, in the specified manner, immediately of its receipt and of any changes in your proposal occasioned thereby.

a. Hand-Carried Proposals shall be delivered to the U.S. Army Corps of Engineers, Omaha District, Contracting Division (Room 301), 106 South 15th Street, Omaha, Nebraska 68102-1618.

b. Mailed Proposals shall be addressed as noted in Item 8 on Page 00010-1 of Standard Form 1442.

3. Offers will be received until 3:00 p.m., local time at place of receiving proposals, 7 MAR 2002.

U.S. Army Engineer District, Omaha
Corps of Engineers
106 South 15th Street
Omaha, Nebraska 68102-1618

22 February 2002
DRL/4547