

DEPARTMENT OF THE ARMY
Omaha District, Corps of Engineers
106 South 15th Street
Omaha, Nebraska 68102-1618

:NOTICE: Failure to acknowledge : Solicitation No. DACA45 02 R 0012
:all amendments may cause rejec- :
:tion of the offer. See FAR : Date of Issue: 26 FEB 2002
:52.215-1 of Section 00100 : **Date of Receiving Proposals:**
05 APR 2002

Amendment No. 0007
02 April 2002

SUBJECT: Amendment No. 0007 to Request for Proposal Solicitation Package for Design and Construction of CONTROL TOWER, US AIR FORCE ACADEMY, CO. Solicitation No. DACA45 02 R 0012.

TO: Prospective Offerors and Others Concerned

1. The specifications and drawings for subject project are hereby modified as follows (revise all specification indices, attachment lists, and drawing indices accordingly).

a. Specifications. (Descriptive Changes.)

(1) Page 01007-25, paragraph 1.11. Delete the last two sentences in the paragraph that read "Exterior communication cables are not part of this contract and provided and installed by others. Placement of manholes and routing of duct bank shall be approved during the review process."

and substitute:

"Exterior communication service entrance cables are not part of this contract and provided and installed by others. Contractor shall coordinate with the Base Communication Squadron to ensure proper space is available at the termination points. Placement of manholes and routing of duct bank shall be approved during the review process."

(2) Page 01007-33, paragraph 1.17. Delete the sentence in the fifth line "Provide the appropriate cable type (coaxial cable (RG-6/U) is believed to be the type) in 21mm conduit from each DDC panel to the patch panels located in the Telephone Equipment Room 122."

and substitute:

"Provide the appropriate cable type, assume RG-6/U coaxial cable in 21mm conduit from each DDC panel to the patch panels located in the Telephone Equipment Room 122. The coaxial cable signal(s) shall be converted for use on fiber optic cables at the patch panels."

(3) Page 01008-7, paragraph 1.2.7.2. Delete the last sentence "Provide wiring from the fire alarm panel to the the communication equipment connected to the central fire station head end equipment."

shown and sized"

and substitute:

"Provide wiring from the fire alarm panel to the terminal block or patch panel as appropriate in the room which will have the main communication service entrance cables terminated. Provide appropriate equipment to convert the signal to continue on fiber optic cable per the requirements of the fire alarm panel manufacturer."

2. This amendment is a part of the proposing papers and its receipt shall be acknowledged on the Standard Form 1442. All other conditions and requirements of the request for proposal remain unchanged. If the proposals have been mailed prior to receiving this amendment, you will notify the office where proposals are received, in the specified manner, immediately of its receipt and of any changes in your proposal occasioned thereby.

a. Hand-Carried Proposals shall be delivered to the U.S. Army Corps of Engineers, Omaha District, Contracting Division (Room 301), 106 South 15th Street, Omaha, Nebraska 68102-1618.

b. Mailed Proposals shall be addressed as noted in Item 8 on Page 00010-1 of Standard Form 1442.

3. Offers will be received until 2:00 p.m., local time at place of receiving proposals, 05 APR 2002.

U.S. Army Engineer District, Omaha
Corps of Engineers
106 South 15th Street
Omaha, Nebraska 68102-1618

02 April 2002
MRP/4413