

DEPARTMENT OF THE ARMY  
Omaha District, Corps of Engineers  
106 South 15th Street  
Omaha, Nebraska 68102-1618

:NOTICE: Failure to acknowledge : Solicitation No. DACA45 03 R 0036  
:all amendments may cause rejec- :  
:tion of the offer. See FAR : Date of Issue: 04 JUN 2003  
:52.215-1 of Section 00100 : Date of Receiving Proposals:  
10 JUL 2003

Amendment No. 0004  
1 July 2003

SUBJECT: Amendment No. 0004 to Request for Proposal Solicitation Package  
Design and Construction of 37TH B1-B SQUADRON OPERATIONS FACILITY,  
FXBM 99-3001, ELLSWORTH AFB, SOUTH DAKOTA.  
Solicitation No. DACA45 03 R 0036.

TO: Prospective Offerors and Others Concerned

1. The specifications and drawings for subject project are hereby modified as follows (revise all specification indices, and attachment lists, and drawing indices accordingly).

a. Specifications. (Descriptive Changes.)

- (1) Section 00010, Page 1, Item 11, delete revisions added by Am #0002 and revise completion time to read "600 calendar days".
- (2) Section 00800, Page 3, paragraph 1.1 added by Am #0002, delete last sentence reading "If exercising of Option Items O-4, O-5 and O-6 does not occur until after 430 calendar days after NTP, an additional 30 calendar days will be added to the overall completion time."
- (3) Section 01007, Page 9, paragraph 1.4, delete second paragraph reading "The Contractor shall convert ... building 8304." and substitute:

"The Contractor shall convert the remainder of the overhead portion of circuit #6 in front of the existing 34th Squad OPS Facility to an underground duct bank and service. Approximately 350 feet of overhead line (4 poles) shall be converted to underground line. This existing overhead line has three spans of conductors with two pole-mounted transformers feeding each Building 8217 and 8304 separately. The existing 34th Squad OPS power source is also tapped into this overhead line. Existing secondary underground feeders may be reused provided they are properly tested."

- (4) Attachment 30 (Part F), Page 23, Item Code LS-1.A, 2.A, 3.A, 4.A, 5.A., Model information for LS-4.A, delete "PA-7002" and substitute "PA-7003".
- (5) Attachment 30 (Part F), Pages 89 and 90, Item Codes T-13.A and T-13.B, Memo note for each item, delete "Inlay items to be

provided by Base" and substitute:

"Inlay items to be provided by Base include uniform patches, maps, scarves, etc., with the thickest item to measure 1/8-inch."

b. Drawings (Not Reissued). The following sheets of drawing code AF 141-32-04 are revised as indicated below with latest revision date of 1 July 2003. These drawings are not reissued with this amendment.

(1) Sheet U1.1.

(a) UTILITY FLAG NOTES, to end of note UF13 revised by Am #0002, add:

"EXISTING SECONDARY UNDERGROUND FEEDERS MAY BE REUSED PROVIDED THEY ARE PROPERLY TESTED."

(b) UTILITY PLAN, near drawing coordinate B-1, delete reference to flag note "UF12" in its entirety.

(2) Sheet A1.1, PLAN FLAG NOTES, add new flag note "O6.4" with the following descriptive requirements:

`COAT CABINET:

(2) UNITS

36" WIDE X 72" TALL X 24" DEEP

PAIR OF DOORS EACH UNIT

CHROME PLATED CLOTHES POLE

PLASTIC LAMINATE = PL-6'

(3) Sheet A1.2, LOWER FLOOR PLAN - AREA B, LOWER COORIDOR 155, outside of TRAINING NCOIC 147 room, to the unidentified cabinet, add flag note designation "O6.4".

2. This amendment is a part of the proposing papers and its receipt shall be acknowledged on the Standard Form 1442. All other conditions and requirements of the request for proposal remain unchanged. If the proposals have been mailed prior to receiving this amendment, you will notify the office where proposals are received, in the specified manner, immediately of its receipt and of any changes in your proposal occasioned thereby.

a. Hand-Carried Proposals shall be delivered to the U.S. Army Corps of Engineers, Omaha District, Contracting Division (Room 301), 106 South 15th Street, Omaha, Nebraska 68102-1618.

b. Mailed Proposals shall be addressed as noted in Item 8 on Page 00010-1 of Standard Form 1442.

3. Offers will be received until 2:00 p.m., local time at place of receiving proposals, 10 JUL 2003.

U.S. Army Engineer District, Omaha  
Corps of Engineers  
106 South 15th Street  
Omaha, Nebraska 68102-1618

1 July 2003  
DRL/4547