

DEPARTMENT OF THE ARMY  
Omaha District, Corps of Engineers  
106 South 15th Street  
Omaha, Nebraska 68102-1618

---

:NOTICE: Failure to acknowledge : Solicitation No. DACW45 02 B 0019  
:all amendments may cause rejec- :  
:tion of the bid. See FAR : Date of Issue: 28 May 2002  
:52.214-3 of Section 00100 : New Date of Opening: 23 July 2002

Amendment No. 0002  
27 June 2002

SUBJECT: Amendment No. 0002 to Specifications and Drawings for Construction of  
Rehab HVAC System, Fort Randall Dam, SD.  
Solicitation No. DACW45 02 B 0019.

TO: Prospective Bidders and Others Concerned

1. The specifications and drawings for subject project are hereby modified as follows (revise all specification indices, attachment lists, and drawing indices accordingly).

a. Specifications. (Descriptive Changes.)

(1) Page 00010-1, delete date and time of bid opening shown and substitute "23 July 2002" at "2:00".

(2) SECTION 15895, PAGE 11, paragraph 2.5.4.6, add new sentence to end of paragraph to read as follows: "All air vents shall be provided with a ball valve for isolation purposes."

(3) SECTION 15895, PAGE 22, paragraph 3.3, delete paragraph in it's entirety.

b. Drawing (Not Reissued). The following drawing sheet is revised as indicated below with latest revision date of 27 June 2002. This drawing is not reissued with this amendment.

1) Sheet M3.02 - add new sentence to the end of Note 3 to read as follows: "BALANCING OF WATER FLOW RATES WILL REQUIRE THAT THE CONTRACTOR SET NEW BALANCING VALVES AND RESET SOME EXISTING BALANCING VALVES."

2. This amendment is a part of the bidding papers and its receipt shall be acknowledged on the Standard Form 1442. All other conditions and requirements of the specifications remain unchanged. If the bids have been mailed prior to receiving this amendment, you will notify the office where bids are opened, in the specified manner, immediately of its receipt and of any changes in your bid occasioned thereby.

a. Hand-Carried Bids shall be delivered to the U.S. Army Corps of Engineers, Omaha District, Contracting Division (Room 301), 106 South 15th Street, Omaha, Nebraska 68102-1618.

b. Mailed Bids shall be addressed as noted in Item 8 on Page 00010-1 of Standard Form 1442.

3. Bids will be received until 2:00 p.m., local time at place of bid opening, 23 Jul 2002.

U.S. Army Engineer District, Omaha  
Corps of Engineers  
106 South 15th Street  
Omaha, Nebraska 68102-1618

27 June 2002  
MFS/4411